

**GOVERNMENT OF TELANGANA.**  
**STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

**From**  
**S. Sandhanna,**  
**District Fire Officer ,**  
**Adilabad.**

**To**  
**The District Educational Officer,**  
**Adilabad district.**

**Re.No.1063/A1/2015, dated:20-10-2015**

**Sir,**

**Sub:-** Telangana State Disaster Response and Fire Service Department – Central Region – Adilabad District – Issuance of No objection certificate for occupancy to the existing building of Ravi High School, Ravi nagar, Nirmal (V&M), Adilabad district- Reg.

**Ref:-** 1). Application Dt: 15-10-2015 correspondent of Ravi High School, Ravi nagar, Nirmal (V&M), Adilabad district.  
2). Section 13(2) of A.P. Fire Services Act, 1999 and Rule 15(2) of A.P. Fire and Emergency Operations and Levy of Fee Rule, 2006.  
3) Chief Office Memo. Rc.No. Instructions of 2305/B2/2007, dated:28-02-2007 & Dated:12-09-2008.  
4) Inspection Report of the Station Fire Officer, Nirmal, on 16-10-2015.

\* \* \* \*

1) In the reference 1<sup>st</sup> cited, of Ravi High School, Ravi nagar, Nirmal (V&M), Adilabad district has reported that he has constructed educational building without obtaining the provisional no objection certificate from this department and requested to issue the No objection certificate for occupancy in terms of reference 3<sup>rd</sup> cited, for existing school by name of Ravi High School, Ravi nagar, Nirmal (V&M), Adilabad district.

2) Vide reference 4<sup>th</sup> cited, the Station Fire Officer, Nirmal has inspected the building on 16-10-2015 and recommended for the issue of no objection certificate for occupancy for the above educational building.

i)Particulars of the Building :

I	Address of the Building	Ravi High School, Ravi nagar, Nirmal (V&M), Adilabad district
II.	Height of the building	09.00 meters.
IV	No. of blocks	One Block
V	No. of Floors	Ground floor + first floor & second floor

ii) Open spaces :

Direction	Required as per NBC	Provided	Deficit
North	NA	13.29 Mtrs	NA
East	NA	48.48 Mtrs	NA
South	NA	20.02 Mtrs	NA
West	NA	05.33 Mtrs	0.77

iii) Floor wise Particulars :

Sl. No.	Floor	Floor area in Sq. meters	Type of Occupancy
1	Ground floor	410.45 Sq. Mtrs	150
	First floor	410.45 Sq. Mtrs	150
	Second Floor	410.45 Sq. Mtrs	150
	Total	1231.35 Sq.Mtrs	450

3) The Management has remitted fire precaution fee Rs.12400/- (Rupees Twelve thousand four hundred only) vide Challan No.18323 Dt:-20-10-2015 at S.B.H branch, Adilabad.

(Cont. 2)



1/2/1

## iv) (a) Means of Escape:

Sl. No.	No. of stair cases	Width of meters	Total Width
1	Internal No's.		--
2	External No's 02	1.50 + 1.50 Mtrs	--
	Total 02	03.00 Mtrs	--

## (b) stair cases :

Highest No. of Students in a floor	Width of Stair cases required (No. of students divided by 50 Meters)	Aggregate width of Staircases provided	Deficit

## v) Fire Safety Measures:

Sl. No.	Fire Safety Measures	Required as per Table 23 of NBC of India, 2005	Provided	Deficiency
1	Fire Extinguishers & Buckets	10 Nos	10 Nos	Nil
2	Hose Reel	N.A	04	Nil
3	Automatic Sprinkler system in basement if area of basement exceeds 200 Sq. meters	N.A	Nil	Nil
4	a) Terrace Tank capacity 10,000 Lts.	N.A	25000	Nil
5	Down comer	N.A	02	Nil
6	a) One Booster pump of 450 LPM	N.A	450	Nil
7	Emergency lighting with battery back up of minimum 4 hrs	N.A	N.A	Nil

4) The Fire safety systems were tested by the committee members during the inspection and performance found satisfactory. Therefore, this office has No Objection for Occupancy Clearance to the existing educational building of Ravi High School, Ravi nagar, Nirmal (V&M), Adilabad district subject to the following conditions.

i	All the fire protection arrangements shall be maintained in good repair as seen during inspection
ii	All the escape / exit routes shall not be kept locked / blocked or encroached.
iii	All the occupants must know the correct method of operation of the fire fighting system installed
iv	Any loss of life or property due to non-functioning of fire safety and other installations shall be the responsibility of the management.
v	All students / staff members of the institution shall be trained to operate the fire safety equipments during emergency.
vi	Addition / alteration, if any in the building may be obtained with prior permission from this Dept.,
vii	Mock drills should be conducted once in 3 months for initial two years. Thereafter once in every 6 months

5) This occupancy clearance is valid up to 30-09-2016. The Management should apply for renewal certificate before 2 months of above validity period.

District Fire Officer,  
Adilabad

Copy to the Station Fire Officer, Nirmal.

**CORRESPONDENT**  
Ravi High School  
Ravi Nagar, NIRMAL.  
Dist: NIRMAL - 504106